

ADDENDUM NO. 2 TO THE IFB #2019-1454

The Alameda-Contra Costa Transit District herewith issues this Addendum No. 2 to the above-referenced INVITATION FOR BID. Except as modified below, all other terms and conditions remain in effect. Strikethrough text represents deletions from the original IFB, and *bold/italicized/underlined text* represent additions to original IFB text.

A. **QUESTIONS AND CLARIFICATIONS:**

- **Question 1:** What is estimated cost for this project?
 - **Response:** The estimated project cost is under \$1,000,000.00.
- **Question 2:** Please provide the information and requirements for fire sprinkler system.
 - Response: An Allowance item is being added to this Addendum for potential fire sprinkler system improvements(see item below). Attached find revised Bid Form with new Fire Sprinkler Allowance in the amount of \$75,000.00
- Question 3: In specification section 07 81 00, p. 2.2.A page 2, sprayed fire-resistive material should be showed on plan A501 and A502 but there is no plan A501 in plans package.
 - Response: A501 was removed and is not listed on the cover and is not part of the current set. The fireproofing spec does not reference Plan A501 or Plan A502 but covers where we need to attach the existing structure. Since it is a scrape (existing), attach and re-coat, our structural engineer did not show it for clarity.
- Question 4: Please provide missed plan's sheet A.503 because the plan A402 has major detail 1/A503 for attachment the new constructed interior wall to existing exterior wall.
 - Response: Attached please find sheet A503.



ADDENDUM NO. 2 TO THE IFB #2019-1454 SECTION 00 41 13 Bid Form - Stipulated Sum

(Single-Prime Contract)

Prices shall reflect <u>all</u> costs for the construction project, including bonds, taxes, permits, insurance, freight, disposal and recycle fees, etc.

BIDDER NAME:	
NAME/TITLE OF PERSON COMPLETING FORM: _	
DATE:	

DESCRIPTION	TOTAL PRICE	
Work for the GO-Customer Service Center Renovation		
Base Bid:	\$	
ALLOWANCE #1: Unforeseen Conditions		
(To include but not be limited to: Hazardous Materials, Code Conflicts, Testing and Special Inspections, etc.)	\$50,000.00	
ALLOWANCE #2: Permits Fees	\$50,000.00	
ALLOWANCE #3: New Fire Sprinkler	\$75,000.00	
Grand Total (Base Bid Cost plus Allowances)	\$	



ADDENDUM NO. 2 TO THE IFB #2019-1454

Plan Sheet A503 Teller Wall Details



